



**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

# ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 09/16/2015  
Received: 09/08/2015  
Sampled By: Max Roccoforte  
Work Order: 5251025

**C** David Douglas School District  
**L** Attn: -  
**I** 11300 NE Halsey St  
**E** Portland OR, 97220  
**N** Phone: (503) 252-2900  
**T**

**Project:** -  
Project #: N/A  
PWSID #: -

Sampling Location: Menlo Park  
Sample Matrix: Water

Lab Number	Sample Name	Sampled: 9/8/15 6:45		Sample Composition:					
<b>5251025-01</b>	Main CW								
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time	
†Lead	1030	EPA 200.9	mg/L	<b>0.017</b>	0.002	0.015	-	09/15/15 16:32 MCLE	

Lab Number	Sample Name	Sampled: 9/8/15 11:00		Sample Composition:					
<b>5251025-02</b>	Bubbler @ 8								
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time	
†Lead	1030	EPA 200.9	mg/L	0.009	0.002	0.015	-	09/15/15 16:32	

Lab Number	Sample Name	Sampled: 9/8/15 11:15		Sample Composition:					
<b>5251025-03</b>	DF-a @ (A) Hall								
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time	
†Lead	1030	EPA 200.9	mg/L	0.002	0.002	0.015	-	09/15/15 16:32	

ND = None detected    MRL = Minimum Reporting Limit    MCL = Maximum Contamination Limit  
MCLE This analyte exceeds the MCL limit.  
†All procedures for this analysis conform to NELAC standards.

Approved by: \_\_\_\_\_

Adriana Gonzalez-Gray  
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.