

**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT
ORELAP Accredited Lab#: OR-100013

Reported: 09/16/2015
Received: 09/08/2015
Sampled By: Max Roccoforte
Work Order: 5251023

C David Douglas School District
L Attn: -
I 11300 NE Halsey St
E Portland OR, 97220
N Phone: (503) 252-2900
T

Project: -
Project # : N/A
PWSID # : -


Sampling Location: Ventura Park
Sample Matrix: Water

Lab Number	Sample Name	Sampled: 9/8/15 7:12		Sample Composition:				
5251023-01	Bubbler @ Rm 8							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	09/15/15 16:32

Lab Number	Sample Name	Sampled: 9/8/15 7:00		Sample Composition:				
5251023-02	Main CW							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	0.026	0.002	0.015	-	09/15/15 16:32 MCLE

Lab Number	Sample Name	Sampled: 9/8/15 7:15		Sample Composition:				
5251023-03	DF-1 (West)							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	0.004	0.002	0.015	-	09/15/15 16:32

ND = None detected **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit
MCLE This analyte exceeds the MCL limit.
†All procedures for this analysis conform to NELAC standards.

Approved by: 
Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.