



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 12/12/2019
Received: 11/22/2019
Sampled By: Adam Ponce
Work Order: 9326005

**C
L
I
E
N
T**
David Douglas School District
Attn: Troy Thompson
11300 NE Halsey St
Portland OR, 97220
Phone: (503) 252-2900

Project:
Project # : N/A
Sample Type :

Sampling Location: Earl Boyles

Lab Number

| | Code | Method | Result | Units | MRL | EPA MCL* | Analysis Date/ Time |
|-------------------|---|-----------|----------------------|-------|-----|----------|---------------------|
| 9326005-01 | Sample Name: 025F Sampled: 11/22/19 6:13 | | Matrix: Water | | | | |
| †Lead | 1030 | EPA 200.9 | ND | ppb | 2 | 20 ppb | 12/11/19 14:54 |
| 9326005-02 | Sample Name: 026F Sampled: 11/22/19 6:14 | | Matrix: Water | | | | |
| †Lead | 1030 | EPA 200.9 | ND | ppb | 2 | 20 ppb | 12/11/19 14:54 |
| 9326005-03 | Sample Name: 126F Sampled: 11/22/19 6:15 | | Matrix: Water | | | | |
| †Lead | 1030 | EPA 200.9 | ND | ppb | 2 | 20 ppb | 12/11/19 14:54 |

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: _____

Adriana Gonzalez-Gray
Laboratory Director