



Professional Laboratory Services

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 07/19/2021
Received: 07/09/2021
Sampled By: Adam Ponce
Work Order: 1190002

CLIENT
David Douglas School District
Attn: Adam Ponce
11300 NE Halsey St
Portland OR, 97220
Phone: (503) 252-2900

Project:
Project #: N/A
Sample Type:

Sampling Location: West Powell Hurst

Lab Number

Table with 8 columns: Lab Number, Code, Method, Result, Units, MRL, EPA MCL*, Analysis Date/ Time. Contains two rows of data for samples 1190002-01 and 1190002-02, including lead levels and sampling details.

ND = None detected at the MRL MRL = Minimum Reporting Limit MCL = Maximum Contamination Limit
†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: [Signature]
Adriana Gonzalez-Gray
Laboratory Director