



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 12/21/2021
Received: 12/13/2021
Sampled By: Adam Ponce
Work Order: 1347002

C
L
I
E
N
T
David Douglas School District
Attn: Troy Thompson
11300 NE Halsey St
Portland OR, 97220
Phone: (503) 252-2900

Project:
Project # : N/A
Sample Type :

Sampling Location: Ron Russell
Sample Matrix: Drinking Water

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
1347002-01	Sample Name: 082 DF (Fixture Replacement) Sampled: 12/9/21 6:30						Matrix: Drinking Water
†Lead	1030	EPA 200.9	ND	ppb	2	15 ppb	12/17/21 12:23

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: _____

Adriana Gonzalez-Gray
Laboratory Director