



Professional Laboratory Services

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 12/26/2023
Received: 12/20/2023
Sampled By: Adam Ponce
Work Order: 3354008

CLIENT
David Douglas School District
Attn: Troy Thompson
11300 NE Halsey St
Portland OR, 97220
Phone: (503) 252-2900

Project:
Project #: N/A
Sample Type:

Sampling Location: Gilbert Park
Sample Matrix: Water

Lab Number

Table with 7 columns: Lab Number, Code, Method, Result, Units, MRL, EPA MCL\*, Analysis Date/ Time. Row 1: 3354008-01, Sample Name: 082DF, Matrix: Water. Row 2: †Lead, 1030, EPA 200.9, 2, ppb, 1, 15 ppb, 12/22/23 12:30.

ND = None detected at the MRL MRL = Minimum Reporting Limit MCL = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb; this is a maximum contamination level for lead in samples, this is not an acceptance level for health based exposure.

Note: Please make sure to send your results to the appropriate agency; Alexin Analytical does not forward these results to any program or person other than the above listed client. It is your responsibility to make sure these results get sent to whichever agency, city, or organization has requested them if these results are for compliance purposes.

Approved by: [Signature]
Adriana Gonzalez-Gray
Laboratory Director